

# CERTIFICATE of Conformity



**Certificate No.:** MK 69241893 0001  
**Test Report No.:** 28207377 002  
**Certificate Holder:** Ventilation Systems JSC  
1, Mikhaila Kotzubinskiego St.,  
UA-01030, Kiev,  
Ukraine  
**Manufacturer:** Ventilation Systems JSC  
1, Mikhaila Kotzubinskiego St.,  
UA-01030, Kiev,  
Ukraine  
**Product:** Room heater

**Identification:**


Type designation:	Rated power input:
VUT 350 EH - 2	3,26kW
VUT 350 EH - 2,2	3,26kW
VUT 350 EH - 3	3,26kW
VUT 500 EH - 2	3,3kW
VUT 500 EH - 2,2	3,3kW
VUT 500 EH - 3	3,3kW
VUT 530 EH - 2	4,3kW
VUT 530 EH - 2.2	4,3kW
VUT 530 EH - 3	4,3kW
VUT 600 EH - 2	4,39kW
VUT 600 EH - 2,2	4,39kW
VUT 600 EH - 3	4,39kW

Rated voltage: 230V, 50Hz  
Protection class: I  
Degree of protection: IP22  
Trade mark: VENTS

**Tested according to:** EN 60335-1:2002+A1+A11+A2+A12+A13+A14  
EN 60335-2-30:2003+A1+A2  
EN 62233:2008

This certificate refers to the above mentioned product. This is to certify that the test sample is in conformity with the requirements stated above. This certificate does not imply assessment of the series-production of the product and does not permit the use of a TÜV Rheinland mark of conformity.

**Date of Issue:**  
Budapest, 2012-04-21



TÜV Rheinland InterCert Kft. – Product Certification Body — H-1132 Budapest, Váci út 48/A-B — www.tuv.hu