

# CERTIFICATE of Conformity



**Certificate No.:** MK 69241592 0001

**Test Report No.:** 28210390 002

**Certificate Holder:** VENTILATION SYSTEMS PrJSC  
1, Mikhaila Kotzubinskiego str.  
UA-01030 Kiev  
Ukraine

**Manufacturer:** VENTILATION SYSTEMS PrJSC  
1, Mikhaila Kotzubinskiego str.  
UA-01030 Kiev  
Ukraine

**Product:** Axial fans

**Identification:**

Type designation:	Rated power input:
VK 100 xy ,	80W
VK 100 Qxy ,	62W
VK 125 xy ,	78W
VK 125 Qx ,	61W
VK 150 xy ,	80W
VK 200 xy ,	107W
VKS 200 xy ,	173W
VK 250 xy ,	173W
VK 250 Qxy ,	108W
VK 315 xy ,	200W
VKS 315 xy ,	285W
Rated voltage:	230V~, 50Hz
Protection class:	II
Degree of protection:	IPX4
where x= U, Un, U1, Uln (function)	
y= blank, R (R = with supply cord and plug)	

**Tested according to:** EN 60335-1:2002+A1+A11+A2+A12+A13+A14  
EN 60335-2-80:2003+A1+A2  
EN 62233:2008

This certificate refers to the above mentioned product. This is to certify that the test sample is in conformity with the requirements stated above. This certificate does not imply assessment of the series-production of the product and does not permit the use of a TÜV Rheinland mark of conformity.

**Date of Issue:**

Budapest, 2011.12.23

